

Reportable Energy Usage and Intensity

By incorporating green conservation into our day-to-day roles, we can contribute to saving money, which in turn can be reallocated to patient care. We recognize the potential environmental impact of our operations and subsequent effect on patients, staff and the community.

The Provincial Government has committed to help public agencies to better understand and manage their energy consumptions. As part of this commitment, Regulation 397/11 under the Green Energy Act, 2009 requires hospitals to report on their energy consumptions and greenhouse gas (GHG) annually.

Reportable energy usage and intensity for Trillium Health Partners is listed below*.

ORGANIZATION NAME	ORGANIZATION TYPE	ADDRESS	<u>CITY</u>	POSTAL CODE	TOTAL FLOOR AREA (ft2)	AVERAGE HOURS/WK	ELECTRICITY (kWh)	NATURAL GAS (M3)	<u>GHG</u> EMISSIONS (KG)	ENERGY INTENSITY (ekWh/ft2)
Credit Valley Hospital	Facilities used for hospital purposes	2200 Eglington Ave. W.	Mississauga	L5M 2N1	982,582.18	168	30,540,500	3,715,057	10,017,978	71.2
Credit Valley Hospital	Facilities used for Administrative purposes	2200 Eglington Ave. W.	Mississauga	L5M 2N1	79,668.83	65	1,607,394	195,529	527,262	46.2
Clinical Administration Building	Administrative offices and related facilities	15 Bronte College Crt	Mississauga	L5B 0E7	124,654.00	65	1,431,469	85,190	301,403	18.7
Mississauga Hospital	Facilities used for hospital purposes	100 Queensway West	Mississauga	L5B 1B8	803,887.90	168	21,345,528	3,160,778	8,068,568	68.3
Mississauga Hospital	Facilities used for Administrative purposes	100 Queensway West	Mississauga	L5B 1B8	65,180.10	65	1,123,448	166,356	424,661	44.3
Queensway Health Centre	Facilities used for hospital purposes	150 Sherway Drive	Toronto	M9C 1A5	353,871.70	168	7,935,719	1,293,349	3,223,258	61.2
Queensway Health Centre	Facilities used for Administrative purposes	150 Sherway Drive	Toronto	M9C 1A5	28,692.30	65	417,669	68,071	169,645	39.7

*As of [January 1, 2011 to December 31, 2011] Revised November 2013